

Product Evaluation

WIN2137 | 1016

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2137 **Effective Date:** October 1, 2016

Re-evaluation Date: September 2020

Product Name: Series Siteline/W-4500 Aluminum Clad Wood Inswing and Outswing Door Transom,

Non-Impact Resistant

Manufacturer: JELD-WEN Windows & Doors

811 Factory St. Hawkings, WI 54530 (800) 535-3936

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Siteline/W-4500 Clad Inswing Transom; (O)	LC-PG50 87 X 24 - TR	+50 / -50 psf
2	Siteline/W-4500 Clad Outswing Transom; (O)	LC-PG50 87 X 24 - TR	+50 / -50 psf

Product Dimensions:

System	Overall Size	Sash Panel Size	Sash Daylight Opening Size
1	87-14" x 24"	85-1/2" x 21-3/8"	80-1/16" x 16-1/4"
2	87-14" x 24"	85-1/2" x 21-3/8"	80-1/16" x 17-5-16"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	JELD-WEN
	Product Name	Siteline Clad In-Swing Transom
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
2	Certification Agency	WDMA
	Manufacturer's Name or Code Name	JELD-WEN
	Product Name	Siteline Clad Out-Swing Transom
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement	
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.	

Acceptance of Smaller Assemblies: Assemblies with dimensions equal to or smaller than those specified are acceptable with the limitations specified in this report.

Installation:

System		
	Type of Installation	New Construction – Wood Frame
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners	Minimum No. 8 x 1-5/8" screws
1, 2	Fastener Location/Spacing	Drive fasteners 4" maximum from each corner and spaced 8" maximum on center thereafter, through the nail fin into the wood buck.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.